

TEST CERTIFICATE

489 1708 156aA

Tests according to EN 489:2009

for

non-welded joint system type

“Heat Shrinkable Joint with Butyl Sealant”

by order of

BGIndustry sp. Z o.o.

Test sample No. 4643, 4644, 4645:

Non-welded joints

on 1x DN 150/250 and 2x DN 80/160

Test report 1467E5296a

The following tests have been completed in accordance with the European Standard
EN 489:2009 at the FFI for three non-welded joints in July/August 2017:

Soil stress test and water impermeability test.

The joints have passed the tests successfully.


Hemmingen, 2017-08-11



Thomas Grage
Managing Director



Max-von-Laue-Str. 23
30966 Hemmingen
+49 511 94370 0
www.fernwaerme.de



Volker Herbst
Project Manager